
Electric Use Trend 1994-2017
Monthly kWh
September Peaks
Every three years average kWh use increased by 100,000 kWh per month peaking in the year 2005. Since that peak, annual kWh has dropped 21% in spite of the addition of 327,000 gross square feet of buildings and the additional equipment that supports them since the year 2000. The addition of a 600 ton electric chiller has also been of minimal impact.
KWH RANGE
2,000,000
1,800,000
1,600,000
1,400,000
1,200,000
1,000,000
800,000
600,000
400,000
200,000
-
7/1/94
7/1/95
7/1/96
7/1/97
7/1/98
7/1/99
7/1/00
7/1/01
7/1/02
7/1/03
7/1/04
7/1/05
7/1/06
7/1/07
7/1/08
7/1/09
7/1/10
7/1/11
7/1/12
7/1/13
7/1/14
7/1/15
7/1/16
7/1/17
YEAR