

## Kohlberg Hall Classrooms



Heating & Cooling System Description  
and  
How it works.

## SWARTHMORE COLLEGE

For Maintenance requests  
Email [workbox@swarthmore.edu](mailto:workbox@swarthmore.edu) or  
Phone X 8280  
The Maintenance web site is;  
<http://www.swarthmore.edu/x17571.xml>

## Room Heating Tips.

Be certain that windows are shut tightly.

Windows that are not completely closed allow cold air into the room.

If your windows won't shut properly call

Facilities Management at x8280 to report the problem.

Closing window shades can help keep the cold out and the heat inside in the winter.

Don't place computers or other appliances near the thermostat as this can fool the thermostat into reducing the heat / cooling supplied to the room.

Shutting off the room lights when the room is not used will reduce the heat the lights put into the room.

**Classrooms must be scheduled through "Space" or the Registrars office to have heating or cooling!**

The heat for Kohlberg Hall is supplied by steam from the boilers in the Heat Plant located across the street from the Field House. The boilers can burn either natural gas or #6 heavy oil. During the coldest weather the College can burn 5,500 gallons of oil a day to heat the various buildings. Cooling is provided by chilled water which comes from either McCabe Library or the chiller plant behind the Science center.

Underground pipes supply the steam to many of the buildings on the Campus. After the steam is used to heat the buildings it condenses back into water that's returned to the Heating Plant to be turned into steam again.

Kohlberg classrooms are provided cooling and ventilation air from vents in the ceiling. This air is supplied from a 40 horsepower air handler in the mechanical room. Heat comes from each room's baseboard radiation.

Each room has its own thermostat to control the space temperature. The thermostats are not adjustable by the room occupants.

College policy for heating in occupied times 68-72°. Thermostats are limited by the automation system to a maximum heating temperature of 72°. Cooling in occupied times is limited to not lower than 73°.

During unoccupied times the heating is reduced and in the summer unoccupied times the air conditioning is off.

Kohlberg is either heating or cooling and as such cooling can not be provided until the heating season is finished.

More College energy information can be found at;  
<http://www.swarthmore.edu/x29161.xml>

# Kohlberg Classroom heating / cooling system.

